

**CERTIFICATE OF SAFE DRINKING WATER AND
SANITARY CONDITION**


No- SSI/AMB/2025/ 638

Dated- 15-12-2025

It is certified that an inspection team headed by Dr. Pawan Kumar, Deputy Civil Surgeon (Health), Ambala Health Department from Civil Surgeon Office Ambala inspected Shri Vidya Sagar Bal Bharti High School, Durga Nagar, Ambala City Dated 12.12.2025 and found that the Shri Vidya Sagar Bal Bharti High School, Durga Nagar, Ambala City has safe drinking water facilities for the students and members of the institution and is maintain the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Govt.

The above Certificate is valid for a period 11.12.2026.

Signature With seal :


15/12/25

Dy. Civil Surgeon (Health)
Ambala

Name : Dr. Pawan Kumar
Designation : Deputy Civil Surgeon (Health), Ambala

Test Report

Lab. ID. No : AMB/10551/12/2025/1667

Memo No : 3030

Report Issue Date: 12/12/2025

ISSUED TO : PRINCIPAL SHRI VIDYA SAGAR BAL BHARTI HIGH SCHOOL DURGA NAGAR, AMBALA CITY- 134003 Sample Description & Type of analysis : Water (Chemical Analysis) Customer Reference No. & Date : NIL & 10.12.2025 Customer Name Who collected sample : MANISH Condition of sample : 2 liter packaged plastic bottle Sample received on dated : 10.12.2025	Date of Analysis started : 10.12.2025 Dated of analysis completed : 10.12.2025 Temperature : 27.5 °C Humidity : 65% RH Sample Quantity : 2 Lt. Source of Sample : GOVT.WATER SUPPLY
---	--

RESULTS


S. No	Parameter	Method Used	Results	Units	IS:10500:2012 (Second Revision)	
					Desirable limit	Max. Permissible limit (in absence better alternate source)
1	Total Dissolved Solids (at 180°C)	APHA,(2540 C) : 2023	438	mg/l	500	2000
2	Total Hardness (as CaCO ₃)	APHA,(2340 C) : 2023	117.6	mg/l	200	600
3	Calcium (as Ca)	APHA,(3500 Ca B) : 2023	23.56	mg/l	75	200
4	Magnesium (as Mg)	APHA,(3500 B) : 2023	14.28	mg/l	30	100
5	Total Alkalinity (as CaCO ₃)	APHA,(2320 B) : 2023	247.45	mg/l	200	600
6	Chloride (as Cl)	APHA,(4500 Cl B): 2023	28.92	mg/l	250	1000
7	Fluoride (as F)	APHA,(4500 F C): 2023	0.5	mg/l	1.0	1.5
8	Nitrate (as NO ₃)	APHA,(4500-NO ₃ B): 2023	1.09	mg/l	45	45
9	pH (at 25°C)	APHA,(4500 H+ B): 2023	7.37	pH units	6.5 to 8.5	No relaxation
10	Iron (as Fe)	IS 3025(Part 53):2023	<0.1	mg/l	1.0	No relaxation
11	Sulphate (as SO ₄)	IS 3025(Part 24):2022	32.76	mg/l	200	400
12	Turbidity	APHA,(2130 B) : 2023	1.22	NTU	1	5
13	Colour	APHA, 2120 B / APHA, 2120 C: 2023	<5	HU	5	15
14	Taste	IS 3025 (Part-8): 2023	Agreeable	Qualitative	Agreeable	Agreeable
15	Odour	IS 3025 (Part-5): 2018	Agreeable	Qualitative	Agreeable	Agreeable

Note: * BDL- Below Detection Limit .

- I The results given above are related to the sample as received and tested in PHED Lab, Ambala Cantt. Reliability of sample lies with the sender/collector.
- II. The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- III. The test report can't be used for any publicity or any legal purpose.
- IV. The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report.
- V. Sample has not been collected by this lab

Sample analyzed by: 
 (Water Analyst)

Reviewed by ()
 Chemist
 PHED Water Testing Laboratory,
 Ambala Cantt

()
 Chemist
 PHED Water Testing Laboratory,
 Ambala Cantt.